SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 95 DATE:

To : AEE, Byatarayanapur ward #6. BBMP. B'lore,

Site : Shakaranagar

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165mm			
2	Total Depth of Bore well Drilled	1170'0"			
3	MS Casing Erected Heavy		135'0"		
4	1st source of water at depth	~~4~~	410'0"		
5	2 nd source of water at depth		495'0"		
6	3rd source of water at depth		560'0"		
7	4th source of water at depth		1130'0"		
8	If any silt, boulders at depth		-NO-		
9	Nature of water		Normal		
10	Motor Pump to used		Yes		
11	Any other remark		—		
12	Total yield of Bore well		2½"		
13					
14					
A.					
B.					
C					

Thanking you

SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 95 DATE:

To : AEE
Byatarayanapura, ward no. 6.
BBMP. Bangalore

Site : Sai George School - Ashwath Nagar

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165 mm			
2	Total Depth of Bore well Drilled		1046'0"		
3	MS Casing Erected Heavy		160'0"		
4	1st source of water at depth		280'0"		
5	2 nd source of water at depth		395'6"		
6	3rd source of water at depth		—		
7	4th source of water at depth		1020'0"		
8	If any silt, boulders at depth		—		
9	Nature of water		Normal		
10	Motor Pump to used		Yes		
11	Any other remark		—		
12	Total yield of Bore well		3"		
13					
14					
A.					
B.					
C					

Thanking you

SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 96 AEE

DATE:

To : Byatarayanapura, Ward #6, BBMP

Site : H.P. School. Sarakpalya.

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165mm	.		
2	Total Depth of Bore well Drilled		1050'04		
3	MS Casing Erected Heavy		148'04		
4	1st source of water at depth		420'04		
5	2 nd source of water at depth		498'04		
6	3rd source of water at depth		784'04		
7	4th source of water at depth		980'04		
8	If any silt, boulders at depth		-No-		
9	Nature of water		Normal		
10	Motor Pump to used		Yes		
11	Any other remark		—		
12	Total yield of Bore well		2½"		
13					
14					
A.					
B.					
C					

Thanking you

SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 92

DATE:

To : AEE
Byatarayanapura, ward no 6, ~~BBMP~~. Bangalore.

Site : Kempanna Home ~~A & B DA~~ Arkavathi

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165mm			
2	Total Depth of Bore well Drilled		1050'0"		
3	MS Casing Erected Heavy		144'0"		
4	1st source of water at depth		389'0"		
5	2 nd source of water at depth		395'0"		
6	3rd source of water at depth		—		
7	4th source of water at depth		980'0"		
8	If any silt, boulders at depth		-No-		
9	Nature of water		Normal		
10	Motor Pump to used		Yes		
11	Any other remark		—		
12	Total yield of Bore well		2"		
13					
14					
A.					
B.					
C					

Thanking you

SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 96 AEE DATE:

To : Byatarayanapura, ward #6, BBMP

Site : Sadiks Layout Near Masjid.

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165mm			
2	Total Depth of Bore well Drilled		1050'0"		
3	MS Casing Erected Heavy		154'0"		
4	1st source of water at depth		398'0"		
5	2 nd source of water at depth		475'0"		
6	3rd source of water at depth		684'0"		
7	4th source of water at depth		998'0"		
8	If any silt, boulders at depth		No		
9	Nature of water		Normal		
10	Motor Pump to used		Yes		
11	Any other remark		-		
12	Total yield of Bore well		2"		
13					
14					
A.					
B.					
C					

Thanking you

SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 98 DATE:

To : AEE
Byatarayanapura ward #6. BBMP.
Bangalore

Site : Bharath Nagar Milk diary Road

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165mm			
2	Total Depth of Bore well Drilled		1040'0"		
3	MS Casing Erected Heavy		135'0"		
4	1st source of water at depth		980'0"		
5	2 nd source of water at depth		350'0"		
6	3rd source of water at depth		670'0"		
7	4th source of water at depth		960'0"		
8	If any silt, boulders at depth		-No-		
9	Nature of water		Normal		
10	Motor Pump to used		Yes		
11	Any other remark		—		
12	Total yield of Bore well		2½"		
13					
14					
A.					
B.					
C					

Thanking you

SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 98 - AEE DATE:

To : Byatarayanapura Sub division BBMP. Bangalore

Site : Anjanayyathi Layout 2nd Cross

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165mm			
2	Total Depth of Bore well Drilled		1050'0"		
3	MS Casing Erected Heavy		131'0"		
4	1st source of water at depth		290'0"		
5	2 nd source of water at depth		350'0"		
6	3rd source of water at depth		590'0"		
7	4th source of water at depth		960'0"		
8	If any silt, boulders at depth		- No -		
9	Nature of water		Normal		
10	Motor Pump to used		Yes		
11	Any other remark		—		
12	Total yield of Bore well		2½"		
13					
14					
A.					
B.					
C					

Thanking you

SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 101 A.E.E. DATE:

To : Byatarayanapura Sub division ward no 6
BBMP, Bangalore

Site : Hegade Nagar II Cross

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165mm			00
2	Total Depth of Bore well Drilled		1046'0"		00
3	MS Casing Erected Heavy		144'0"		00
4	1st source of water at depth		470'0"		00
5	2 nd source of water at depth		598'0"		00
6	3rd source of water at depth		-		00
7	4th source of water at depth		980'0"		00
8	If any silt, boulders at depth		-No.		00
9	Nature of water		Normal		00
10	Motor Pump to used		Yes		00
11	Any other remark		—		00
12	Total yield of Bore well		2½"		00
13					00
14					
A.					
B.					
C					

Thanking you

SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 103 AEE DATE:

To : Byatarayanapura Subdivisim
Ward #16, BBMP Bangalore,

Site : Dasarahally BBMP Office

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165mm			00
2	Total Depth of Bore well Drilled		1056'04		00
3	MS Casing Erected Heavy		72'04		00
4	1st source of water at depth		380'04		00
5	2 nd source of water at depth		480'04		00
6	3rd source of water at depth		560'04		00
7	4th source of water at depth		940'04		00
8	If any silt, boulders at depth		—		00
9	Nature of water		Normal		00
10	Motor Pump to used		Yes		00
11	Any other remark		—		00
12	Total yield of Bore well		2½		00
13					00
14					
15					
A.					
B.					
C					

Thanking you

SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 94 DATE:

To : AEE, Byatarayanapura Ward #6 BBMP.

Site : Church Street.

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165mm			00
2	Total Depth of Bore well Drilled		1120'		00
3	MS Casing Erected Heavy		131'0"		00
4	1st source of water at depth		385'		00
5	2 nd source of water at depth		480'		00
6	3rd source of water at depth		—		00
7	4th source of water at depth		990'		00
8	If any silt, boulders at depth		No.		00
9	Nature of water		Normal		00
10	Motor Pump to used		Yes		00
11	Any other remark		—		00
12	Total yield of Bore well		3" water.		00
13					00
A.					
B.					
C					

Thanking you

SAI BOREWELLS

No 4. Tp lane, SJP Road cross, Bangalore-560002 Mob: 9845096308

BOREWELL WORK REPORT

NO : 105 **DATE:**

To : AEE, Byatarayanapura Ward # 6

Site : Telecom Layout 4th Cross

Sl.No	DESCRIPTION		Feet	Remark	Ps.
1	Size of Bore well Drilled	165 mm			00
2	Total Depth of Bore well Drilled	1040'			00
3	MS Casing Erected Heavy	1280'			00
4	1st source of water at depth		390'		00
5	2 nd source of water at depth		–		00
6	3rd source of water at depth		450'0"		00
7	4th source of water at depth		1015'		00
8	If any silt, boulders at depth		-NO-		00
9	Nature of water		Normal		00
10	Motor Pump to used		Yes		00
11	Any other remark		–		00
12	Total yield of Bore well			2½"	00
13					00
14					00
15					00
16					00
17					00
18					
A.					
B.					

Thanking You